

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1
Issued January 15, 2016
Requests for Bids
Roadway Improvement Project
Haverhill Road – Christine Lane to Atkinson Road
Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."

Addendum #1

Issued January 15, 2016

Requests for Bids

Roadway Improvement Project

Haverhill Road – Christine Lane to Atkinson Road

Salem, New Hampshire

Notice to Bidders:

This addendum No. 1 revises, clarifies and becomes part of the bid documents issued and dated 12/28/2015, for the Roadway Improvement Project – Haverhill Road – Christine Lane to Atkinson Road. Receipt of this addendum must be acknowledged in the Bid Form.

Bid Clarifications

1. The Owner intends to complete tree cutting which is anticipated to be trees 3" and larger in diameter prior to issuing the Notice to Proceed for this project. The General Plans, sheets 15 through 24, include notes "Remove Tree" and "Remove Trees", and with this addendum these notes shall be updated to address the removal of stumps meaning "Remove Stump" and "Remove Stumps". Removal of stumps shall be paid by the unit, "Each", under Item No. 201.23. The Contractor shall be responsible for the removal of trees and brush, smaller than 3" in diameter under this project and this work is to be included with the grubbing operations and paid as a final quantity under Item 201.2 – Grubbing (F). The items in the contract noted as Clearing and Grubbing – Item 201.01, Removal of Small Trees – Item 201.21, and Removal of Large Trees – Item 201.22 are intended to cover additional work as may be directed by the Engineer and Owner.
2. The Special Provision, Section 900.5 – Ledge Probes is clarified with this addendum by adding the following to paragraph 1.2: "The ledge probes under Item No. 900.5 are directed and executed by the Contractor for the sole purpose of the Contractor's benefit."
3. The Special Provision, Section 900.112 – Precast Headwalls (12" – 18" Only), Section 900.13 – Special Precast Headwalls (Custom 30"), Section 900.14 – Precast Headwalls (30" Only) is clarified with this addendum by adding the following paragraph 3.3 under Construction Requirements: "Headwalls on the south side of Haverhill Road, labeled on the plan as HW403, HW404 and HW406, are to be placed in close proximity to one another without gaps between the individual headwalls. The Contractor shall provide a submission to the Engineer and Owner addressing the work at this location prior to starting the related work. The Contractor shall coordinate closely with the Engineer and Owner prior to and during the placement of these headwalls. At the seams along the edges of the headwalls include fabric, mortar, and associated materials meeting the requirements of the NHDOT standard specifications and so as to meet the Owners intent, and this work shall be considered subsidiary and incidental to the headwall items with no additional compensation."