

Request for Qualifications
Maintenance and Repair of Emergency Generators
Town of Salem, NH
June 2018
RFQ (2018-022)

ADDENDUM No. 2

QUESTIONS: Answers in bold italic

July 18, 2018:

1. **QUESTION:** Who holds the contract presently?

There is no contract in place.

2. **QUESTION:** What is the response time once call is placed to the Location with the Emergency?

Section 2: Scope of Services

B. Response Time

Able to respond to emergency repairs within 24 hours and within 48 hours for non-emergency repair

3. **QUESTION:** What is the KW of Units

See Addendum #1 for response

4. **QUESTION:** Annual Major PM Service with Oil, or Minor Pm Service as well (2 calls a year per unit?)

Section 2: Scope of Services

A. *Emergency Generator Annual Maintenance*